Local Limits:

Spokane County has established Local Limits in its Pretreatment Ordinance 8.03A.0204:

A. The following limits are established as Local Limits, expressed as maximum daily ("Daily Maximum") concentrations ("Daily Maximum Limits"). No User or other Person may discharge wastewater into the POTW (which may convey wastewater to the Spokane County Regional Water Reclamation Facility) in excess of the following concentrations:

Arsenic: 0.41 mg/L.

Benzene, toluene, ethylbenzene, and xylene (BTEX) = a sum of these four constituents' analytical results not to exceed 1.4 mg/L.

Cadmium: 0.07 mg/L.

Total Chromium: 117 mg/L.

Copper: 1.7 mg/L.

Cyanide: 1.9 mg/L.

Fats, oils and, grease: See SPOKANE COUNTY CODE 8.03A.0201 B 19.

Lead: 0.32 mg/L.

Mercury: 0.05 mg/L.

Nickel: 3.98 mg/L.

Non-polar material (or total petroleum hydrocarbons): Not to exceed 100 mg/L.

Silver: 1.7 mg/L.

Zinc: 5.6 mg/L.

The pH limit set in SPOKANE COUNTY CODE 8.03A.0201 B(2) may also be enforced as a Local Limit.

Molybdenum: 1.5 mg/L.

Selenium: 1.7 mg/L.

The above limits apply at any point of introduction into any sewer or portion of the POTW (which may convey wastewater to the Spokane County Regional Water Reclamation Facility).

B. The following limits are established as Local Limits, expressed as maximum daily ("Daily Maximum") concentrations ("Daily Maximum Limits"). No User or other Person may discharge wastewater into the POTW (which conveys wastewater solely to the Riverside Park Water Reclamation Facility) in excess of the following concentrations:

Arsenic: 0.41 mg/L.

Benzene, toluene, ethylbenzene, and xylene (BTEX) = a sum of these four constituents' analytical results not to exceed 1.4 mg/L.

Cadmium: 0.11 mg/L

Total Chromium: 117 mg/L.

Copper: 1.9 mg/L.

Cyanide: 1.9 mg/L.

Fats, oils and, grease: See SPOKANE MUNICIPAL CODE 13.03A.0201 B 19.

Lead: 0.32 mg/L.

Mercury: 0.05 mg/L.

Nickel: 3.98 mg/L.

Non-polar material (or total petroleum hydrocarbons): Not to exceed 100 mg/L.

Silver: 1.7 mg/L.

Zinc: 5.6 mg/L.

The pH limit set in SPOKANE MUNICIPAL CODE 13.03A.0201 B(2) may also be enforced as a Local Limit.

Molybdenum: 1.5 mg/L.

Selenium: 1.7 mg/L.

The above limits apply at any point of introduction into any sewer or portion of the POTW (which conveys wastewater solely to the Riverside Park Water Reclamation Facility).

Where a User is subject to a Categorical Pretreatment Standard and a Local Limit for a given Pollutant, the more stringent limit applies as the Applicable Pretreatment Standard.